

+1 (817) 668-0628 info@aeroblazelab.com www.aeroblazelab.com

Aeroblaze Laboratory Inc. 12819 Harmon Rd. Bldg 575 Fort Worth, TX 76177 USA

						Report # 1763.1		
	Powe	rplant F	ire Pen	etration	n Test Ro	esults		
Regulation:	on: 14 CFR 25.1193(d) Criteria: Advi		Advisory Circu	Advisory Circular No. 20-135 Procedu		DOT/FAA/AR-00/12, Chapter 12		
Customer Information				Sample Notes				
Celli	Block Fire Containm 234 Northeast Standish, Maine		LIBIK Product Line Fire Containment Bags					
Flame 1	emperature: 2000	°F ± 100 °F	Heat	Flux Density:	9.3 Btu/ft²-sec	or 4,500 BTU/hr minimum		
Sample	Flame Time (min:sec)		Burnthrough? (Yes/No)		/No)	Backside Ignition? (Yes/No)		
1	30:00			No		No		
	Acceptance	Criteria		1 —	Result	& Designation		
The sample must withstand flame penetration and no exhibit backside ignition for the required test time. »Fire-Resistant: 5 minutes »Fire-Proof: 15 minutes				X PASS FAIL X Fire-Resistant X Fire-Proof				
Notes:								
The results or amendments of	on the date testing was per	obtained in complia formed, unless othe	ance with the listed	d requirements and, problaze applies a pa	/or specifications. A ass/fail criteria based	mendment levels are that of the current d on the outcome of the test regardless of y be applied. This test report shall not be		

reproduced, except in full, without written approval from Aeroblaze Laboratory Inc. The test results relate only to the items tested.

Tested by: Andrew Feghali & Leslie Gardner 13-Feb-19

Lab Manager & Lab Engineer

Approval:

13-Feb-19

Andrew Feghali, Lab Manager, DER

1 of 2 TP-12-01 Rev A

+1 (817) 668-0628 info@aeroblazelab.com www.aeroblazelab.com


Aeroblaze Laboratory Inc. 12819 Harmon Rd. Bldg 575 Fort Worth, TX 76177 USA


Report # 1763.1


Powerplant Fire Penetration Test Results

Regulation: 14 CFR 25.1193(d) Criteria: Advisory Circular No. 20-135 Procedure: DOT/FAA/AR-00/12, Chapter 12

FLAME CALIBRATION SUMMARY







TP-12-01 Rev A 2 of 2